

## Fire and Emergency Services

Vadodara Mahanagar Seva Sadan Dandia Bazar, Vadodara 390209 Phone: 2413635, 2413754

0.w.Mo. 2054/19-20

## TO WHOM SOEVER IT MAY CONCERN

This is to certify that Gujarat Public School, SBG Campus, Plot No. 1, Nr. Toll Naka, Chhani, Vadodara – 390024 have installed following types of portable Fire Extinguisher at their School premises for Fire and Safety purpose.

1.	5 Kg. DCP Type Fire Extinguishers	04 Nos.
2	9 Ltrs. Water CO2 Type Fire Extinguishers	02 Nos.
3.	2 Kg CO2 ABC Type Fire Extinguishers	08 Nos.
4.	5 Kg CO2 ABC Type Fire Extinguishers	06 Nos.

We have given advice to the PRO of the school to train the staff and the watchman and also children to how to operate and where to operate the fire extinguishers in case of small fire and keep always all fire extinguishers in working condition.

We are also enclosing herewith some important suggestions for fire and safety kindly follows it strictly

This certificate is issued on written request from the school for one year period from 7/09/2019 to 06/09/2020.

Enel: Fire & Safety suggestions for Educational School.

Copy to :-

Gujarat Public School SBG Campus Nr. Toll Naka, Chhani, Vadodara. 390024

Chief Officer (Fire) Mahanagar Seva Sadan, Vadodara

Principal SCHOOL

GUJARAT PUBLIC SCHOOL

Chhani, Vadodara.

ON THE STATE OF TH